

:
Wastewater Treatment Plant – Lift Station “A”
January 2010

<u>TIME</u>	<u>Pump#1</u> <u>Reading</u>	<u>Hrs. Ran</u>	<u>GPD</u>	<u>Pump#2</u> <u>Reading</u>	<u>Hrs. Ran</u>	<u>GPD</u>
	31			31		
	30			30		
	29			29		
09:44 AM	28	13986.8		28	30988.2	
09:35 AM	27	13976.4		27	30983.1	
06:49 AM	26	13964.6	11.3	26	30975.2	6.9
07:55 AM	25	13953.9	11.7	25	30969.3	6.5
10:36 AM	24	13941.3	10.5	24	30962.2	8.8
06:28 AM	23	13932.9	6.1	23	30951.8	10.5
06:33 AM	22	13929.0	3.5	22	30941.2	10.0
11:00 AM	21	13925.9	3.8	21	30931.7	10.6
11:00 AM	20	13921.5	4.4	20	30920.0	11.7
09:45 AM	19	13917.1	4.4	19	30908.3	11.7
10:00 AM	18	13912.8	4.3	18	30895.7	12.6
08:19 AM	17	13907.5	5.3	17	30883.3	12.4
06:34 AM	16	13902.0	5.5	16	30870.5	12.8
06:39 AM	15	13898.4	3.6	15	30856.3	14.2
09:16 AM	14	13895.5	2.9	14	30843.9	12.4
09:52 AM	13	13891.5	4.0	13	30833.5	10.4
07:28 AM	12	13885.5	6.0	12	30822.6	10.9
06:56 AM	11	13879.7	5.8	11	30810.1	12.5
08:39 AM	10	13873.9	5.8	10	30800.7	9.4
06:35 AM	9	13867.8	6.1	9	30789.3	11.4
11:33 AM	8	13864.3	3.5	8	30781.9	7.4
09:40 AM	7	13857.8	6.5	7	30772.3	9.6
08:41 AM	6	13851.5	6.3	6	30762.1	10.2
07:59 AM	5	13843.7	7.8	5	30753.1	9.0
09:25 AM	4	13835.5	8.2	4	30747.1	6.0
06:25 AM	3	13824.0	11.5	3	30741.9	5.2
06:29 AM	2	13812.0	12.0	2	30733.9	8.0
09:17 AM	1	13802.8	9.2	1	30727.4	6.5

*Note Gallons/Day = Pumping Rate x Hours x 60

#1 Pumping Rate = 28 GPM

#2 Pumping Rate = 28 GPM

Example: 28 x 2.6 hrs. x 60/1000000 = MG

Village of Winslow
Wastewater Treatment Plant – Lift Station “A”
January 2010

<u>TIME</u>	<u>Pump#3</u> <u>Reading</u>	<u>Hrs. Ran</u>	<u>GPD</u>	<u>Muffin Monster</u> <u>Reading</u>	<u>Hrs. Ran</u>
	31			31	
	30			30	
	29			29	
09:44 AM	28	5021.0		28	41444.2
09:35 AM	27	5018.2	2.8	27	41444.2
06:49 AM	26	5015.3	2.9	26	41444.2
07:55 AM	25	5013.2	2.1	25	41444.2
10:36 AM	24	5011.2	2.0	24	41444.2
06:28 AM	23	5008.1	3.1	23	41444.2
06:33 AM	22	5006.3	1.8	22	41444.2
11:00 AM	21	5004.0	2.3	21	41444.2
11:00 AM	20	5002.0	2.0	20	41444.2
09:45 AM	19	5000.0	2.0	19	41444.2
10:00 AM	18	4998.4	1.6	18	41444.2
08:19 AM	17	4995.9	2.5	17	41444.2
06:34 AM	16	4993.4	2.5	16	41444.2
06:39 AM	15	4991.7	1.7	15	41444.2
09:16 AM	14	4990.0	1.7	14	41444.2
09:52 AM	13	4987.2	2.8	13	41444.2
07:28 AM	12	4984.3	2.9	12	41444.2
06:56 AM	11	4982.3	2.0	11	41444.2
08:39 AM	10	4979.8	2.5	10	41444.2
06:35 AM	9	4977.1	2.7	9	41444.2
11:33 AM	8	4975.4	1.7	8	41444.2
09:40 AM	7	4972.5	2.9	7	41444.2
08:41 AM	6	4969.8	2.7	6	41444.2
07:59 AM	5	4967.6	2.2	5	41444.2
09:25 AM	4	4965.2	2.4	4	41444.2
06:25 AM	3	4963.2	2.0	3	41444.2
06:29 AM	2	4960.3	2.9	2	41444.2
09:17 AM	1	4958.3	2.0	1	41444.2

*Note Gallons/Day = Pumping Rate x Hours x 60
#3 Pumping Rate = 85 GPM

Example: 85 x 2.6 hrs. x 60/1000000 = MG