

Village of Winslow
Wastewater Treatment Plant – Lift Station “B”
January 2010

<u>TIME</u>		<u>Pump#1</u> <u>Reading</u>	<u>Hrs. Ran</u>	<u>GPD</u>		<u>Pump#2</u> <u>Reading</u>	<u>Hrs. Ran</u>	<u>GPD</u>
	31							
	30							
	29							
09:33 AM	28	10886.7			28	14084.3		
09:24 AM	27	10880.9	5.8	.02958	27	14076.6	7.7	.03927
06:17 AM	26	10873.6	7.3	.03723	26	14067.1	9.5	.04845
07:41 AM	25	10868.1	5.5	.02805	25	14059.1	8.0	.04080
10:23 AM	24	10862.1	6.0	.03060	24	14052.4	6.7	.03417
06:16 AM	23	10855.7	6.4	.03264	23	14044.8	7.6	.03876
06:24 AM	22	10851.5	4.2	.02142	22	14039.6	5.2	.02652
09:30 AM	21	10847.8	3.7	.01887	21	14035.3	4.3	.02193
11:00 AM	20	10843.1	4.7	.02397	20	14030.0	5.3	.02703
09:00 AM	19	10838.3	4.8	.02448	19	14023.0	7.0	.03570
09:45 AM	18	10833.1	5.2	.02652	18	14015.7	7.3	.03723
08:05 AM	17	10827.7	5.4	.02754	17	14008.0	7.7	.03927
06:21 AM	16	10822.0	5.7	.02907	16	14000.6	7.4	.03774
06:26 AM	15	10817.1	4.9	.02499	15	13994.3	6.3	.03213
08:58 AM	14	10812.5	4.6	.02346	14	13988.3	6.0	.03060
09:36 AM	13	10807.2	5.3	.02703	13	13981.0	7.3	.03723
07:20 AM	12	10801.3	5.9	.03009	12	13973.5	7.5	.03825
06:48 AM	11	10795.5	5.8	.02958	11	13965.4	8.1	.04131
08:25 AM	10	10790.2	5.3	.02703	10	13958.4	7.0	.03570
06:24 AM	9	10784.7	5.5	.02805	9	13951.5	6.9	.03519
11:19 AM	8	10781.3	3.4	.01734	8	13947.4	4.1	.02091
09:19 AM	7	10776.0	5.3	.02703	7	13940.8	6.6	.03366
08:37 AM	6	10770.7	5.3	.02703	6	13934.1	6.7	.03417
07:51 AM	5	10765.2	5.5	.02805	5	13927.7	6.4	.03264
09:21 AM	4	10760.7	4.5	.02295	4	13922.5	5.2	.02652
06:20 AM	3	10755.6	5.1	.02601	3	13915.1	7.4	.03774
06:25 AM	2	10748.8	6.8	.03468	2	13905.9	9.2	.04692
09:40 AM	1	10743.8	5.0	.02550	1	13899.2	6.7	.03417

*Note: Gallons/Day = Pumping Rate x Hours x 60

#1 Pumping Rate = 85 GPM

#2 Pumping Rate = 85 GPM

Example: 85 x 2.6 hrs. x 60/1000000 = MG