

Winslow Well and Pump House

January 2010

Date	Time	Reading	Gallons	Pump 1 Hrs.	Hours Ran	Pump 2 Hrs.	Hours Ran	Fluoride (lbs.)	Usage (lbs.)	Fluoride Test (Plant) (mg/l)	Fluoride Test (Dist.) (mg/l)	Chlorine (lbs.)	Usage (lbs.)	Chlorine Test (mg/l)	pH RAW	pH TP01	Remarks
01-01	09:27 AM	34679000	29700	1390.39	0.00	1361.07	2.39	321.0	1.5	0.9	0.9 (N)	295.0	1.0	0.9 (N)			
01-02	06:14 AM	34708700	29400	1390.39	2.38	1363.46	0.00	319.5	1.0			294.0	1.0				
01-03	10:29 AM	34738100	38800	1392.77	0.81	1363.46	2.35	318.5	1.5			293.0	1.0				
01-04	09:09 AM	34776900	19800	1393.58	1.56	1365.81	0.00	317.0	1.0	1.2	1.2 (W)	292.0	1.0	0.9 (W)			
01-05	07:45 AM	34796700	27800	1395.14	0.00	1365.81	2.24	316.0	1.0	1.2	1.1 (C)	291.0	1.0	0.7 (C)			
01-06	08:31 AM	34824500	27600	1395.14	2.23	1368.05	0.00	315.0	1.0	1.1	1.1 (N)	290.0	1.0	0.6 (N)			
01-07	05:29 PM	34852100	57600	1397.37	2.36	1368.05	2.28	314.0	3.0	1.2	1.1 (W)	289.0	2.0	0.5 (W)			
01-08	10:59 AM	34909700	0	1399.73	0.00	1370.33	0.00	311.0	0.0	1.2	1.1 (C)	287.0	0.0	0.6 (C)			
01-09	06:21 AM	34909700	42600	1399.73	1.03	1370.33	2.40	311.0	1.5			287.0	1.5				
01-10	08:15 AM	34952300	46400	1400.76	1.39	1372.73	2.35	309.5	2.0			285.5	2.0				
01-11	06:38 AM	34998700	27800	1402.15	2.27	1375.08	0.00	307.5	1.0	0.9	0.9 (N)	283.5	1.0	0.5 (N)			Bac-T's to Lyons Labs; Fluoride to Springfield
01-12	07:14 AM	35026500	38400	1404.42	0.57	1375.08	2.53	306.5	2.0	1.1	1.1 (W)	282.5	2.0	0.8 (W)			Bac-T's come back safe
01-13	09:25 AM	35064900	28500	1404.99	2.31	1377.61	0.00	304.5	1.0	1.0	1.1 (C)	280.5	1.0	0.5 (C)			
01-14	08:54 AM	35093400	27900	1407.30	0.00	1377.61	2.23	303.5	1.0	1.0	1.0 (N)	279.5	1.0	0.5 (N)			
01-15	06:22 AM	35121300	28500	1407.30	2.31	1379.84	0.00	302.5	1.5	1.0	1.1 (W)	278.5	1.0	0.5 (W)			
01-16	06:15 AM	35149800	29800	1409.61	0.00	1379.84	2.38	301.0	1.0			277.5	1.0				
01-17	07:53 AM	35179600	30000	1409.61	2.42	1382.22	0.00	300.0	1.0			276.5	0.5				
01-18	09:00 AM	35209600	32900	1412.03	0.00	1382.22	2.63	299.0	1.0	1.0	0.9 (N)	276.0	0.0	0.3			9 A.M. CL offline; fixed at 11:00 A.M.
01-19	09:00 AM	35242500	29400	1412.03	2.38	1384.85	2.01	298.0	1.0	1.5	1.1 (W)	276.0	0.0	.0 (N)			9 A.M. CL offline; MM Quill repair 3:15 P.M.
01-20	11:00 AM	35271900	30800	1414.41	0.08	1386.86	0.39	297.0	2.0	0.9	1.0 (C)	276.0	0.5	.0 (C)			CL offline – 4:30 CL 1.0 @ TP Raw & Final to MM
01-21	09:00 AM	35302700	28900	1414.49	2.19	1387.25	0.14	295.0	1.0	1.0	1.1 (C)	275.5	1.5	.1 (N)			
01-22	06:16 AM	35331600	27100	1416.68	0.00	1387.39	2.18	294.0	1.0	0.9	.9 (W)	274.0	1.0	1.0 (W)			
01-23	06:07 AM	35358700	29500	1416.68	2.37	1389.57	0.00	293.0	2.0			273.0	1.0				
01-24	10:17 AM	35388200	30400	1419.05	0.00	1389.57	2.42	291.0	1.0			272.0	1.0				
01-25	07:30 AM	35418600	28700	1419.05	2.31	1391.99	0.00	290.0	1.0	1.3	1.2 (N)	271.0	1.0	1.0 (N)			
01-26	06:09 AM	35447300	42000	1421.36	1.06	1391.99	2.29	289.0	2.5	1.2	1.2 (W)	270.0	2.0	1.0 (W)			
01-27	09:11 AM	35489300	46700	1422.42	1.32	1394.28	2.46	286.5	2.0	1.4	1.2 (C)	268.0	2.0	0.8 (C)			
01-28	09:20 AM	35536000		1423.74		1396.74		284.5		1.4	1.2 (N)	266.0		0.8 (N)			
01-29																	
01-30																	
01-31																	

Totals:

Average:

# Daily Pump Figures

(gallons per day)

